

Humidity Sensor

Data
and
Application notes
Ver. 2



Table of Conents

	Page
1. SPECIFICATIONS	1
1-1 General Specifications	1
1-2 Typical Humidity Sensor Characteristics (Fig. 1)	2
1-3 Temperature and Humidity Characteristics of CGS-H14 (Table 1)	3
1-4 Typical Humidity Response Characteristics (Fig. 2)	4
1-5 Configuration Outline (Figs. 3 & 4)	5
(a) CGS-H14	5
(b) CGS-G14DL	6
1-6 CGS-H14/DL Reliability Test Results	7
2. MEASUREMENT OPERATION AND ACCEPTANCE TEST USING HUMIDITY SENSOR	9
2-1 Measurement Precautions :	9
2-2 Measurement Operation :	10
(a) With impedance analyzer (Fig. 5)	11
(b) With A/C Voltmeter and AF oscillator (Fig. 6)	12
3. COMPARISON WITH MECHANICAL HUMIDITY CONTROL	13
3-1 Advantages of Electronic Humidity Control	13
3-2 Comparative Table of Electronic and Mechanical Humidity Control	14
4. CIRCUIT EXAMPLES	15
4-1 CGS-H14DL Applications	15
(1) Circuit example	15
(2) Circuit adjustment	17
(3) Output characteristics (Fig. 9)	19

Table of Contents (cont.)

	Page
(4) Example of control circuit with an indicator using CGS-H14DL (Fig. 10)	20
(5) Circuit example of simple humidity checker (Fig. 11)	21
4-2 CGS-H14 Applications	22
(1) Circuit example	22
(2) Circuit adjustment	24
(3) Output characteristics (Fig. 14)	26
5. CGS-H14/DL MOUNTING EXAMPLE	27
5-1 Mounting in Air-conditioner	27
5-2 Mounting of Sensor in Dehumidifier	32
5-3 Mounting of Sensor in Humidifier	33
5-4 Extension of Sensor Wiring	34
6. METHOD OF KNOWN HUMIDITY GENERATION FOR PERFORMANCE TEST OF SENSOR	36
6-1 Method of Known Humidity Generation	36
6-2 Saturated Salt Solution	37
(1) Humidity fixed point table (Table 5)	38
(2) Necessary materials (Fig. 20)	39
(3) How to make saturated salt Solution	40

Introduction

In general, it has been considered difficult to make a **high-Performance** hygrometer or humidity Controller with a humidity sensor-

Chichibu Cement's humidity **sensor** CGS-H14 has **changed** this concept. Its easy to use features and high reliability **allow** anyone to apply this **sensor** to other equipment.

With this **manual**, we hope to promote the development of high-quality humidity equipment **which** incorporates our humidity Sensors.


You **can** rely on our long and extensive experience with humidity Sensors.

If you have any questions, pertaining to the data included here, please contact us. We will **be** happy to assist you in every way.

NOTICE

The information in this document is **subject** to **change** without **notice** and should not **be construed** as **commitment** by CHICHIBU CEMENT Co., Ltd.

No part of this document may be photocopied, **reproduced** or translated to another language without the **prior written** Permission of CHICHIBU CEMENT Co., Ltd.

SCIMAREC and the SCIMAREC logo  are registered trademarks of SCIMAREC Co., Ltd.

#182630

1. SPECIFICATIONS

1-1 General Specifications

1. Part Name : Humidity Sensor
2. Type Name : CGS-H14
3. Storage Temperature Range : 0 ~ 50°C
4. Storage Humidity Range : 10 ~ 90% RH,
w/o condensation
5. Storage/Operating Environment : avoid condensation,
freeze-up, dust, mist, oil,
alcohol; corrosive gases or
any other dirty/anomalous
environment.
6. Operating Humidity Range : 30 ~ 90% RH
7. Operating Temperature Range: 0 ~ 50°C
8. Rated Working Voltage : AC 1 V (50 Hz - 1 kHz)
9. Rated Power : 0.3 mW
10. Nominal Impedance Value : 60 kΩ (at 25°C, 50% RH)
11. Impedance Value Tolerance : +30 kΩ (nominal value $\pm 3 \sigma$)
12. Typical Characteristics : Shown in Fig. 1.
13. Typical Humidity Response Characteristics : Shown in Fig. 2.
14. Reliability (Impedance value change with relative humidity
at 25°C, 50% RH)
 - 14-1 Dry Heat Test : <+5% RH (85°C, 1000 hrs)
 - 14-2 Cold Test : <+5% RH (-40°C, 1000 hrs)
 - 14-3 Damp Heat Test : <+5% RH
(65°C, 90% RH, 1000 hrs)
 - 14-4 Low Humidity Test : <±5% RH (<20% RH, 1000 hrs)
 - 14-5 Change of Temperature Test : <+5% RH
(-40°C ~ +85°C, 100 cs)
 - 14-6 Dewing Cycle Test : <±5% RH (200 cs)
15. Dimensions : Shown in Fig 3.

1-2 Typical Humidity Sensor Characteristics




Fig. 1 Typical Characteristics

1-3 Temperature and Humidity Characteristics of CGS-H14

Table 1. Typical Humidity Sensor Characteristics
 AC 1 V, 1 kHz unit: k Ω

	0 °C	5 °C	10 °C	15 °C	20 °C	25 °C	30 °C	35 °C	40 °C
15 %RH	-	-	-	-	-	-	18500	9800	4900
20 %RH	-	-	-	-	14000	7800	4300	2500	1300
25 %RH	-		16000	8200	4200	2300	1350	790	460
30 %RH	-	11000	5900	3100	1600	890	560	360	215
35 %RH	7600	4200	2300	1250	710	410	265	165	105
40 %RH	3000	1700	980	560	330	190	128	85	56
45 %RH	1450	820	480	270	165	100	68	46	32
50 %RH	760	440	245	135	88	55	38	27	19
55 %RH	420	235	135	77	49	32	23	16.5	12
60 %RH	225	130	77	46	29	19.5	15	10.5	7.6
65 %RH	128	77	46	28	18.51	12.31	9	6.71	5.1
70 %RH	73	45	28	18	12	8	6	4.5	3.4
75 %RH	45	28	18	11.5	7.8	5.4	4	3	2.4
80 %RH	28	18	11.5	7.3	5.1	3.6	2.7	2.1	1.6

1-4 Typical Humidity Response Characteristics




Fig. 2 Typical Humidity Response Characteristics

1-5 Configuration Outline

(a) CGS-H14







Fig. 3 Configuration Outline (CGS-H14)

(b) CGS-G14DL



- ① Resistor $1k\Omega$ 1/6 W
- ② Temperature Compensator
- ③ Humidity Sensor

Fig. 4 Configuration Outline (CGS-H14DL)

1-6 CGS-E14/DL Reliability Test Results

[1] Durability Tests

- | | |
|------------------------------------|--|
| (1) High temperature | $\leq +1\%$ RH (85°C, 1000 hrs) |
| (2) Low temperature | $\leq +1\%$ RH (-40°C, 1000 hrs) |
| (3) High humidity | $\leq +1\%$ RH
(40°C, 93% RH, 1000 hrs) |
| (4) Low humidity | $\leq +1\%$ RH (20% RH, 1000 hrs) |
| (5) Dewing cycle | $\leq +2\%$ RH (10 min dewing, 20 min
drying, 200 cs) |
| (6) Rapid change of
temperature | $\leq +1\%$ RH (-40°C ↔ 85°C, 100 cs) |
| (7) High humidity and load | $\leq +2\%$ RH
(AC 0.5 V, 1 kHz, 1000 hrs) |
| (8) High temperature and
load | $\leq +2\%$ RH
(AC 1 V, 1 kHz, 1000 hrs) |
| (9) Load Life | $\leq +1\%$ RH
(AC 1 V, 1 kHz, 1000 hrs) |
| (10) Damp heat | $\leq +3\%$ RH
(60°C, 90% RH, 1000 hrs) |

[2] Environment Tests

- | | |
|----------------------|--|
| (1) Methanol | $\leq +1\%$ RH (10,000 ppm, 200 hrs) |
| (2) Ethanol | $\leq +1\%$ RH (10,000 ppm, 200 hrs) |
| (3) Ammonia | $\leq +3\%$ RH (10,000 ppm, 200 hrs) |
| (4) Acetic acid | $\leq +2\%$ RH (10,000 ppm, 200 hrs) |
| (5) Cigarette smoke | $\leq +3\%$ RH (1 cigarette/liter) |
| (6) CO ₂ | $\leq +2\%$ RH (2,000 ppm, 200 hrs) |
| (7) H ₂ S | $\leq +1\%$ RH (50 ppm, 200 hrs) |
| (8) Ultra Violet ray | $\leq +2\%$ RH (1000 hrs) |
| (9) Oil mist | $\leq +2\%$ RH
(180°C, 20 cm above, 1000 hrs) |

[3] Mechanical Tests

- | | |
|---------------------------|-------------------|
| (1) Drop test | No visible damage |
| (2) Lead tensile strength | No visible damage |
| (3) Lead bending strength | No visible damage |
| (4) Vibration test | No visible damage |

[4] Others

- | | |
|--------------------------|--|
| (1) Room environment | $\leq \pm 1\%$ RH (1000 hrs) |
| (2) Low temperature load | $\leq +1\%$ RH (-40°C, AC 1 V, 1 kHz) |
| (3) Temperature cycle | $\leq \pm 1\%$ RH (-30°C ~ 60°C, 100 cs) |
| (4) Overload | $\leq +1\%$ RH
(AC 2.5 V, 1 kHz, 1000 hrs) |
| (5) Insecticide | $\leq +1\%$ RH
(30 sec. spray 1 m away from
the sensor face) |
| (6) Hair spray | $\leq +1\%$ RH
(30 sec. spray 1 m away from
the sensor face) |
| (7) Freon | $\leq \pm 1\%$ RH (10,000 ppm, 200 hrs) |
| (8) Organic solution | $\leq +3\%$ RH
(B:T:X=3:3:4, saturated
atmosphere, 1000 hrs) |
| (9) Light oil | $\leq +2\%$ RH (1000 hrs) |
| (10) Kerosene | $\leq +1\%$ RH (1000 hrs) |
| (11) Mosquito repellent | $\leq +2\%$ RH
(burns 1 coil in 5-l Container) |

2. MEASUREMENT OPERATION AND ACCEPTANCE TEST OF HUMIDITY SENSOR

2-1 Measurement Precautions

Make sure to apply A/C for measurement with the sensor.

If measured by ohm-meter, it causes damage to the sensor. Our test is conducted pursuant to the procedures on page 11 (Fig. 5).

Since impedance analyzers are not widely used, when you want to measure only sensor data, follow the procedures on page 12 (Fig. 6). With this method the reliability of the data is lost in a high impedance environment, e.g., low humidity. With careful measurement, however, reliable data can be obtained up to the level of minimum humidity of 30% RH using this method!

Thus., it is sufficient for such acceptance test of materials (products) conducted by users.

Please note the following;

- (1) NEVER apply D/C to the Sensor.
- (2) Keep the effective value of A/C voltage below 1 Vrms for continuous use and 2.5 Vrms for short-time use of less than 10 min-
- (3) Start the measurement only after the humidity of the generator becomes stabilized. (Refer to Section 6 for precautions in using a humidity generator-)

2-2 Measurement Operation

With an impedance analyzer, measurement is done **simply** by **reading** the displayed **figures**. Make **sure** to **perform** the **Short/Open** correction before reading. The measured **f** igure is the absolute value of impedance.

Obtain the impedance with the following formula when using **A/C** Voltmeter and **A/C** power supply unit (or Audio Freq. Oscillator).

$$Z_s = R * (V_s/V_o - 1) \quad (\Omega)$$

where **Zs** = impedance of humidity **sensor**

R = loaded resistance

VS = output voltage of generator

Vo = voltage generated at load ends

Please note that the upper **limit** is **about 1 kHz**. The **higher** the measured **frequency**, the greater the error.

(Especially the **error** due to frequency characteristics of Voltmeter and Circuits stray capacitance.)

(a) With impedance analyzer





Fig. 5 Measurement with CGS-H14DL (1)

(b) With A/C Voltmeter and AF oscillator



How to calculate impedance

$$Z_s = R \left[\frac{V_s}{V_o} - 1 \right] [\Omega]$$

Note: The **input** impedance of Voltmeter must sufficiently be greater than the loaded resistance.

Fig. 6 Measurement with CGS-H14DL (2)

3. COMPARISON WITH MECHANICAL HUMIDITY CONTROL

3-1 Advantages of Electronic Humidity Control

Conventionally, humidity controllers (mechanical controllers) which operate based on elasticity of nylon ribbon or hair have been used.

Recently **new electronic controllers** which incorporate a humidity **sensor** have appeared.

Two **types** of the controllers are compared **in this section** to determine which is more advantageous in manufacturing **current** humidity-related equipment,

Owing to improved performance and decreased **cost** of humidity sensors, the popularity of **electronic** humidity control is growing at present. **However, since electronic** humidity control requires some **peripheral equipment** other than **sensor** itself, it **may not** be affordable in practice in those **cases** where **cost** is the primary concern.

Users prefer high-quality **products** as a trend. Also it is **important** to satisfy users in the terms of **cost** by added **product value**. A comparison was made on next page between mechanical and **electronic** control of humidity. We hope that it will assist the reader to make decisions. It is **our belief** that the data **presented** in the **comparative** table are **sufficient** to convince the reader that for high-quality, high-performance, high value-added **products** which will occupy the main stream in coming years, the utmost advantage will be gained by employing **electronic** control systems with humidity **sensors**.

3-2 Comparative Table of Electronic and Mechanical Humidity Control

Table 2

Performance, function, etc.	Electronic humidity control (with humidity sensor)	Mechanical humidity control (Nylon ribbon)
1. Precision	With appropriate circuit design, an error level of +2% of accuracy can be attained. Optimum circuit can be selected according to the required accuracy.	It is hard to achieve an accuracy level of +5% error . Freedom of selection is limited.
2. Function	Other than circuit control, display, alarm and other additional functions are available . The control method is not limited only to simple ON/OFF switching,	ON/OFF control only . Display is available only in simple readout scale . Cannot be applied to make high value-added products .
3. Life	Currently used humidity Sensors have sufficiently long life. If used properly , life lasts as long as other electronic parts .	The parts do not require high precision , thus they can be used for a long time if one does not care the wear .
4. Price, costs	Sensor cost is decreasing, yet, still more expensive compared with mechanical control systems . Increase in sales price of finished products possible.	Quite inexpensive, because no other device needed.
i 5. Response speed	Very fast . Also, circuit design allows desired response time. Humidity control and monitoring of environment where conditions are always changing is possible .	It is impossible to develop fast-responding equipment . It cannot cope with fast-changing environment.
6. Hysteresis	Hysteresis particular to Sensors is less than 1-2% RH . According to the control principle, a wide range of design is possible . Can remove instability of control loop.	Other than nylon ribbon hysteresis, major hysteresis is caused by mechanical play. Highly precise control is not possible.

4. CIRCUIT EXAMPLES

4-1 CGS-H14DL Applications

(1) Circuit example

CGS-H14DL examples are given.


CGS-H14DL comprises the CGS-H14 Humidity Sensor and sensor incorporating temperature compensation and logarithmic compression.

A circuit with the desired output regardless of degree of humidity can be designed by logarithmic compression of changing impedance characteristics of Sensor.

Actual application circuit and adjustment method are given in the following pages. On page 20 (Fig. 10), a circuit diagram for humidity indication/controller is given. This circuit has five LED indicators for humidity change and also the relay is activated when humidity reaches the fixed point set at the variable resistor.

This can be used as humidity indicator and control circuit of humidifiers and air-conditioners.

Also on page 21 (Fig. 11), a circuit diagram of simplified humidity checker with a meter indicator is given. The change of humidity is indicated by an analog meter, which can be used as a simple humidity Checker.



HC-870410A

CGS-H14DL


Parts List

NO.		NO.	
U 1a,b	Dual OP Amp TL-062CP (FET Input)	C 1	Elect. Cap. 47uF/25WV
D 1	SI SW Diode 1S1588 / Toshiba	C 2	Elect. Cap. 22uF/25WV
D 2	SI SW Diode 1S1588 / Toshiba	C 3	Elect. Cap. 47uf/16WV
D 3	SI SW Diode 1S1588 / Toshiba		
D 4	SI Rectifier 10D1 / IR	HS 1	Humidity Sensor CGS-H 14DL
ZD 1	Zenner Diode RD-6A / NEC (Vz=6v)		
R 1	Resistor 1 K ohm 1/4w J		
R 2	Resistor 11k ohm 1/4w J		
R 3	Resistor 20k ohm 1/4w F		
R 4	Resistor 100k ohm 1/4w F		
R 5	Resistor 330K ohm 1/4w J		
R 6	Resistor 470 ohm 1/4w J		
VR 1	Variable Resistor 200k ohm B		

HC-870410A

CGS-H14DL

Fig. 7 Application Note Table 3 Parts List



HC-B70412A | CGS-H 14DL/ADJ

Fig. 8 How to Adjust

(2) Circuit adjustment

Connect $22\text{ k}\Omega$ and $51\text{ k}\Omega$ fixed resistors (error $\leq \pm 1\%$) as sensor dummy as shown above.

Next, adjust the variable resistor VR1 so that the output voltage (V_o) becomes 1.40 V.

Then, the output characteristics of a Standard sensor are shown on next page.

Since the CGS-14 has stable Performance, accuracy with $\pm 5\%$ RH error level can be attained with this adjustment,

If much higher accuracy is required, **adjustment** and **inspection** are required using a Standard humidity generation bath, etc.

For details on the Standard humidity generation bath, refer to **Section 6**, which explains the humidity generation method for Performance **test**, or make inquiry to us.

(3) Output characteristics





Fig. 9 Output Characteristics HA870410A



U1a, b ; TL-062C or TL-082C (FET Input)
 U2, U3 ; LM324-N
 U4 ; μ A 7808C

Fig. 10 Humidity Indicator (with relay control)




Fig. 11 Humidity Checker (Analog Meter)

- U_1 ; TL-062CP (or 7L-062CP)
 U_2 ; LM358C
 $D_1 \sim D_5$; 1N914 (or 1S1588)
 D_6 ; LED (Red)
 D_7 ; Zener Diode $V_Z = 4.25V$

4-2 CGS-H14 Applications


(1) Circuit example

Example is given when CGS-H14 and a temperature compensation thermistor are used.

Output from the humidity sensor is rectified and temperature compensated with the thermistor, then output.

The thermistor cannot perfectly compensate the sensor temperature change against drastic change of ambient temperature. Make sure to use it in an appropriate condition.

It can be used for simple humidity checking and control.



HC-870412A

CGS-H14

Parts List /


NO.		NO.	
U 1	OP Amp LM358N,LM324N etc	C 1	Elect. Cap. 0.047uF/50WV
D 1	Si SW Diode 1S1588 / Toshiba	C 2	Elect. Cap. 2.2uF/25WV
D 2	Si SW Diode 1S1588 / Toshiba	C 3	Elect. Cap. 22 uF/16WV
Th 1	Thermistor $R_{25}=50Kohm$ $B=4100k$	HS 1	Humidity Sensor CGS-H 14
R 1	Resistor 2K ohm 1/4w J		
R 2	Resistor 1 k ohm 1/4w J		
R 3	Resistor 22k ohm 1/4w J		
R 4	Resistor 82k ohm 1/4w J		
R 5	Resistor 62K ohm 1/4w J		
R 6	Resistor 10K ohm 1/4w J		
VR 1	Variable Resistor 200kohm B		

HC-870412A

CGS-H14

Fig. 12 Application Note

Table. 4 Parts List



HC-870412A

CGS-H14

Fig.13 How to Adjust

(2) Circuit adjustment

Connect a $50\text{ k}\Omega$ ($\leq +1\%$) resistor as **sensor dummy** and a $50\text{ k}\Omega$ ($\leq +1\%$) resistor for thermistor dummy as shown above.

Next, **adjust** the variable resistor VR1 so that the output voltage (Vo) **becomes** 1.05 V.

Then, with a Standard Sensor, the output characteristics shown on next page are obtained.

As CGS-14 has stable Performance, accuracy of $\pm 5\%$ RH error level can be attained with this adjustment (provided that the ambient temperature is $24 \pm 5^\circ\text{C}$).

If much higher accuracy is required, a circuit using
CGS-H14DL (refer to page 15) is recommended.

For details , please make inquiry to us.

(3) Output characteristics




Fig. 14

5. CGS-H14DL MOUNTING EXAMPLE .

The where and how of mounting a humidity **sensor** not only **affects** its Performance **but** also greatly influences **sensor life**. Thus, mounting circumstances are crucial to the reliability of the control unit itself. In this **section**, the mounting of Sensors is described.

5-1 Mounting in Air-conditioner

There are two possible ways of mounting a humidity **sensor** in an air-conditioner. **One** is to mount the **sensor** in the incoming air flow. The advantages of this mounting are as follows:

a) Fast **response**

The humidity **sensor responds faster** when the surrounding air is **flowing**.

b) Higher accuracy

Higher accuracy can be expected by this direct measurement of incoming air.


The disadvantages of this mounting are as follows:

a) The **sensor deteriorates faster** due to direct exposure to unclean air.

b) The humidity of the incoming air is **controlled**, which may not coincide with the humidity **condition** of a **particular room**.

Fig. 15 on the next page shows an example of mounting a sensor in the incoming air flow. In this case, the humidity sensor is placed so that its back faces the incoming air. This way prevents dust and smoke particles in the air from sticking to the surface of the humidity sensor, improving sensor life. The response time and accuracy are scarcely affected by mounting the sensor backwards. Therefore, we recommend the sensor be mounted so that the sensor surface does not directly face the air flow.

(See the Fig. 15 on the next page.)



Another way of mounting is to **place** the **sensor** outside the incoming **air flow**.

The advantages of this mounting are as **follows**:

a) Longer **sensor** life

There is less **chance** of deleterious substances **sticking** to the surface of the **sensor**, and therefore a lower degree of dirt **can** be **expected**.

b) More **comfortable** ambient conditions **can** be expected when the **sensor** is installed on a wireless Controller, etc.

The disadvantages of this mounting are as follows:

a) Possible delay of **response time**

As the **sensor** is not **placed** in the **active** air flow, the 'control **speed** 'may be slower when the surrounding air does not **sufficiently** circulate.

Fig. 16 on the next page gives examples of mounting a **sensor** outside the air flow. When mounting the **sensor** on the main body of the air-conditionor, it is most common to put it near the air inlet for **better response speed**. It is also possible to mount the **sensor** on the wireless Controller, and then transmit the humidity data to the main Controller.

(See Fig. 16 on the next **page**.)




Fig. 16 Mounting Example of Humidity Sensor in Air-conditioner (2)

5-2 Mounting of Sensor in Dehumidifier

The humidity sensor can be mounted in a dehumidifier in almost the same manner as in air-conditioners, that is, in the air flow or outside the air flow.

The advantages and disadvantages are the same as with an air-conditioner. Please select the best way to suit your requirements.

(An example is illustrated below.)




Fig. 17 Mounting Example of Humidity Sensor in Dehumidifier

5-3 Mounting of Sensor in Humidifier

In the case of a humidifier, it is most economical to mount the sensor on the control board. It can also be placed on the outside surface, which does not improve the performance but appeals to consumers in that the humidifier is controlled by a sensor.

For general use satisfactory performance is achieved if the sensor is mounted in the air flow created by a fan. In this case, the same precautions should be taken as in the case for air-conditioners concerning dirt on the sensor. It is effective to put a filter at the air inlet. (An example is given below.)




Fig. 18 Mounting Example of Humidity Sensor in Humidifier

5-4 Extension of Sensor Wiring

With some equipment, a **sensor cannot** be mounted directly on the printed circuit board. In such **cases**, it is necessary to extend the wiring from the **sensor**. When extending the wiring from the **sensor**, one should note the following items:

- (1) Use shielded cables for extension.
- (2) Wiring extension **affects** the Performance especially in a low humidity environment. Pay special attention when a humidity range of 10 - 20% RH is involved in measurement and control.
- (3) **Watch** out for noise. Sensor impedance **can reach** 10 Mn' in low **humidity**.
- (4) When the lowest limit of **measured (controlled)** humidity is 40% RH **and** the extension distance is less than 50 **cm**, it is not necessary to use shielded cables. In that **case**, take special note of noise.

******* For the use of shielded **cables**, refer to the following diagram.




Fig. 19 Extension of Sensor Wiring

6. METHOD OF KNOWN HUMIDITY GENERATION FOR PERFORMANCE TEST OF SENSOR

To test the circuit design and Performance of the equipment incorporating a humidity **sensor**, stable and accurate known humidity generation is **necessary**.

Humidity generation is also needed for acceptance test of the Sensor.

Here, a simple, economical and also accurate way of making fixed humidity **points** without elaborate equipment will be discussed.

6-1 Methods of Known Humidity Generation

The following methods have **been** used for this purpose.

1) Saturated salt Solution

2) Method of **changing** both temperature and **pressure**

The **latter** method needs **special** equipment and it is not easy to acquire the required experimental apparatus.

Thus, the **former** method using saturated salt solution will be discussed here. However, when **efficient inspection** for large quantities of **products (inspection of mass production)** is needed, the **second** method is recommended.

*** We do not recommend the use of a **constant** temperature bath with a humidity generation **function** because it **cannot** provide a stable humidity. Therefore we **cannot** reply to inquiries concerning data obtained using such apparatus.

6-2 Saturated Salt Solution

Dissolve a specific salt solute into demineralized water and put the Solution into a air-tight Container. Then, the air confined in the Container with the Solution will attain a specific relative humidity depending on the kind of salt used. This equilibrium is used to make humidity fixed **points**. The only materials needed for this method are the followings:

- 1) Salt **solutes** (for the number of fixed **points** needed)
- 2) Demineralized water
- 3) **Plastic** Containers (for the the number of fixed **points** needed)
- 4) **Small** fan for air **agitation**
- 5) Others (adhesives for sealing, etc.)
- 6) Constant temperature **bath** when **higher** accuracy is required.


For the kinds of "**salt**," refer to the table on next **page**.

(1) Humidity fixed point table


Table 5 Humidity Fixed Points by Kind of Salt

Temp. (°C)	Lithium chloride	Magnesium chloride	Magnesium nitrate	Sodium chloride	Potassium chloride
	LiCl (%RH)	MgCl ₂ (%RH)	Mg(NO ₃) ₂ (%RH)	NaCl (%RH)	KCl (%RH)
0	11.23±0.54	33.66±0.33	60.35±0.55	75.51±0.34	88.61±0.53
5	11.26±0.47	33.60±0.28	58.86±0.43	75.65±0.27	87.67±0.45
-10	11.29±0.41	33.47±0.24	57.36±0.33	75.67±0.22	86.77±0.39
15	11.30±0.35	33.30±0.21	55.87±0.27	75.61±0.18	85.92±0.33
20	11.315±0.311	33.07±0.18	54.38±0.33	75.47±0.14	85.11±0.29
25	11.30±0.27	32.78 _{fp} ±0.16	52.89±0.22	75.29±0.12	84.34±0.26
30	11.28±0.24	32.44±0.14	51.40±0.24	75.09±0.11	83.62±0.25
35	11.25±0.22	32.05±0.13	49.91±0.29	74.87±0.12	82.95±0.25
40	11.21±0.21	31.60±0.13	48.42±0.37	74.68±0.13	82.32±0.25
45	11.16±0.21	31.10±0.13	46.93±0.40	74.52±0.16	81.74±0.28
50	11.10±0.22	30.54±0.14	45.44±0.66	74.43±0.19	81.20±0.31
55	11.03±0.23	29.93±0.14		74.41±0.24	80.70±0.35
60	10.95±0.26	29.26±0.18		74.50±0.30	80.25±0.41
65	10.86±0.29	28.54±0.21		74.71±0.37	79.85±0.48
70	10.75±0.33	27.77±0.25		75.06±0.45	79.49±0.57
75	10.64±0.38	26.94±0.29		75.58±0.55	79.17±0.66
80	10.51±0.44	26.05±0.34		76.29±0.65	78.90±0.77


(2) Necessary materials




(1) Salt




(2) , Demineralized water



(3) Small fan



(4) Air-tight Containers (plastic)



(5) Sealing adhesive (Silicone Sealant, etc)

Note: Use plastic containers only.
Some salts erode metals.

Fig. 20 Necessary Materials

(3) How to make saturated **salt** Solution

- 1) Prepare demineralized water of 40 - 60°C (500 cc for **each** salt, though minor adjustment may be necessary depending on the Container).
- 2) Put the salt in a Container and gradually add **the** water. "**Saturated**" state means that salt is not dissolved completely, thus you should observe a **little** salt still remaining. Take **care** not to add too **much** water.
- 3) Cover the Container with a **lid** and **seal**. Let it stand at least for 6 h for the Solution **adjust** to room **temperature**. It is recommended, therefore, to prepare a large quantity of saturated water at one time when many humidity **fixed points** are needed.

Fixed points can be **made** with the above method.


When using the **solution**, please note the following:

- 1) If the **container** is opened and shut, wait 20 min. before measuring.
- 2) Agitate the air constantly with the fan. Keep the fan just strong enough to agitate the **air** thoroughly in the Container. If the solution's surface is rippled, it is too strong. If **the** agitation is too strong, tiny Solution **particles** will be released and such **particles** cause the **sensor** to deteriorate when they adhere to the **sensor** surface.

3) If the temperature of the **solution** has **changed**,
let the Solution stand for 2 - 4 h before
measurement.


Keeping the above precautions and correctly
controlling the temperature, allows the saturated
salt Solution method to be **effective** with a
reproductivity of +1% RH.

The method of making saturated **salt** solution is
illustrated below.




Fill in any crevice.

(2)



(3)



(5) Finished




Fig. 21